

Air Quality Monitoring	
Monitoring Point	42
Monitoring Point Location	BOILER NO.4 STACK
Licensee	SHOALHAVEN STARCHES PTY LTD, 160 Bolong Rd Bomaderry NSW 2541
EPA Licence Number	883 EPA's Public Register: <a href="https://app.epa.nsw.gov.au/prpoeoapp/">https://app.epa.nsw.gov.au/prpoeoapp/</a>
Monitoring Frequency	Continuous

Month	Results Obtained	Pollutant	Units	Min. value	Max. value	Average value	100 percentile limit	Exceedances	Explanatory Note
September 2019	7-Oct-19	Opacity	%	0	0.53	0.15	20	nil	
October 2019	6-Nov-19	Opacity	%	0.05	7.54	1.08	20	nil	
November 2019	10-Dec-19	Opacity	%	0	0.28	0.09	20	nil	
December 2019	7-Jan-20	Opacity	%	0	0.16	0.08	20	nil	
January 2020	11-Feb-20	Opacity	%	0.04	0.37	0.14	20	nil	
February 2020	12-Mar-20	Opacity	%	0.0	0.85	0.16	20	nil	
March 2020	10-Apr-20	Opacity	%	0.1	0.49	0.28	20	nil	
April 2020	14-May-20	Opacity	%	0	0.30	0.10	20	nil	
May 2020	13-Jun-20	Opacity	%	0	0.47	0.09	20	nil	
June 2020	15-Jul-20	Opacity	%	0.01	0.16	0.06	20	nil	
July 2020	14-Aug-20	Opacity	%	0	0.35	0.15	20	nil	
August 2020	13-Sep-20	Opacity	%	0	5.21	1.68	20	nil	
September 2020	15-Oct-20	Opacity	%	1.32	8.21	5.16	20	nil	
October 2020	10-Nov-20	Opacity	%	0.03	5.05	2.62	20	nil	
November 2020	3-Dec-20	Opacity	%	0.73	7.79	3.94	20	nil	
December 2020	4-Jan-21	Opacity	%	0.01	4.19	1.58	20	nil	
January 2021	2-Feb-21	Opacity	%	1.26	3.17	2.13	20	nil	
February 2021	10-Mar-21	Opacity	%	0.39	9.80	3.44	20	nil	
March 2021	9-Apr-21	Opacity	%	9.05	12.79	10.95	20	nil	
April 2021	3-May-21	Opacity	%	2.72	12.41	6.35	20	nil	
May 2021	14-Jun-21	Opacity	%	0.97	11.97	6.75	20	nil	
June 2021	12-Jul-21	Opacity	%	0.25	16.56	4.05	20	nil	
July 2021	2-Aug-21	Opacity	%	0.49	3.20	1.39	20	nil	
August 2021	9-Sep-21	Opacity	%	1.06	6.49	3.56	20	nil	
Month	Results Obtained	Pollutant	Units	Min. value	Max. value	Average value	100 percentile limit	Exceedances	Explanatory Note
September 2021	5-Oct-21	Opacity	%	4.89	9.88	7.31	20	nil	
October 2021	8-Nov-21	Opacity	%	6.62	12.83	8.61	20	nil	

November 2021	6-Dec-21	Opacity	%	0.59	2.74	1.20	20	nil	
December 2021	10-Jan-22	Opacity	%	0.74	3.92	2.19	20	nil	
January 2022	14-Feb-22	Opacity	%	1.95	3.76	2.52	20	nil	
February 2022	7-Mar-22	Opacity	%	2.08	6.81	4.00	20	nil	
March 2022	11-Apr-22	Opacity	%	0	5.48	3.41	20	nil	
April 2022	13-May-22	Opacity	%	0	5.92	2.60	20	nil	

Note: Coal-fired Boiler 4 de-commissioned and converted to gas -fired boiler